

Proposed Values for Uninstructed Imbalances for the Year 2016

Report to the Regulatory Authorities

28 August 2015



Table of Contents

1. Executive Summary	3
2. TSC Obligations	4
3. Uninstructed Imbalance Parameters.....	5
4. MW Tolerance (MWTOL) and Engineering Tolerance (ENGTOL)	6
4.1 Basis for Parameters	6
4.2 Proposed Values.....	6
5. System per Unit Regulation Parameter (UREG)	8
5.1 Basis for Parameter.....	8
5.2 Proposed Value.....	8
6. Discount for Over-Generation (DOG) and Premium for Under-Generation (PUG).....	9
6.1 Basis for Parameters	9
6.2 Proposed Values.....	9
7. Conclusion	11

1. Executive Summary

Uninstructed Imbalances apply in the Single Electricity Market (SEM) when the Actual Output of a Generator Unit deviates from its Dispatch Quantity in a Trading Period. This report to the Regulatory Authorities sets out the proposed 2016 values for the five parameters used in the calculation of Uninstructed Imbalances, accompanied by relevant justification and background.

It is the System Operators' opinion that these parameter values provide adequate economic signals at present and that no change is currently warranted. As such, the System Operators propose that the parameter values for 2016 remain unchanged.

2. TSC Obligations

Paragraph 4.142 of the Single Electricity Market (SEM) Trading and Settlement Code (version 17.0) requires the System Operators to make a report to the Regulatory Authorities at least 4 months before the start of the Year¹ proposing values for the five parameters outlined below used in the calculation of Uninstructed Imbalances for that Year.

The parameters are:

1. Engineering Tolerance, ENGTOL
2. MW Tolerance, MWTOL
3. System per Unit Regulation parameter, UREG
4. Discount for Over Generation, DOG
5. Premium for Under Generation, PUG

This document is the System Operators' joint submission under Paragraph 4.142.

¹ "Year" defined as per Trading and Settlement Code (Version 17.0) glossary: "means a period commencing at 00:00h on 1 January and ending at 24:00h on the next occurring 31 December."

3. Uninstructed Imbalance Parameters

All dispatchable generation is required to follow instructions from the control centres within practical limits to ensure the safe and secure operation of the power system. Failure to do so will lead to increased constraint costs as the System Operators would be required to re-dispatch other generation at short notice to account for the mismatch in actual and instructed generation and could, at worst, lead to system blackout. Thus, economic signals to ensure that dispatchable generation follows instructions within acceptable practical limits are required. In SEM, the Uninstructed Imbalance mechanism, as set out in the Trading and Settlement Code, provides such signals.

The Uninstructed Imbalance mechanism should provide economic signals that:

- are sufficient to ensure generators follow dispatch instructions
- are cost related – where possible
- are not unreasonably punitive
- avoid perverse incentives

A change to one individual parameter would require revision of the other parameters used in the Uninstructed Imbalance mechanism to ensure the correct economic signals are maintained. For example, any change to the tolerance band would necessitate a review and likely further change to the adjustment factors applicable outside of the tolerance band in order to recover the costs to the system of the Uninstructed Imbalance and to maintain the necessary incentive to comply with dispatch instructions.

4. MW Tolerance (MWTOL) and Engineering Tolerance (ENGTOL)

4.1 Basis for Parameters

The System Operators have a duty to operate the power system in a safe, secure and economic manner for the benefit of all consumers. Maintaining the demand/supply balance, and thus system frequency, within strict limits is crucial to the management of power system security. The importance of maintaining system frequency close to 50 Hz is demonstrated by the use of system frequency as a power quality metric around the world. Frequency control is maintained by carrying reserves of spare capacity on the system.

As the power system of Ireland and Northern Ireland does not have AC interconnection with other power systems, frequency control is more challenging than for a large interconnected system². Deviation of a generating unit from its dispatch instruction will have a direct impact on system frequency and on the reserve available to the system operator for frequency control. This effect is amplified on smaller power systems. Thus, all generating units are required to follow dispatch instructions from the control centres.

In operation, even at constant steady state frequency, a generator instructed to a given MW value is unlikely to be able to maintain its output at exactly the dispatched MW level for any period of time. This may be due to tolerances in machine design, precision of measurements, the provision of reactive power, varying instantaneous calorific quality of fuel input and deviations in general thermodynamic conditions. However, over a period of time the average output of the unit should be manageable within a small tolerance.

To account for these practical limits, the Uninstructed Imbalance mechanism in the SEM includes a tolerance band. When the system is operating at nominal system frequency, this tolerance band is defined as the maximum of (a) the MW Tolerance and (b) the Engineering Tolerance multiplied by the Dispatch Quantity. When the system frequency deviates from the nominal frequency, it is expected that generators vary their output to compensate – this is known as frequency regulation. The impact of frequency regulation on the Uninstructed Imbalance mechanism is addressed in Section 5.

4.2 Proposed Values

MW Tolerance MWTOL

The MW Tolerance is a MW value that defines the minimum MW tolerance at nominal frequency within which a generating unit is deemed to be complying with its dispatch instruction. The MW tolerance for generators varies worldwide, with the majority ranging from 1 MW to approximately 10 MW, when such a tolerance is used³. These values are dependent on a number of factors including the size of the power system, the settlement mechanism for the deviation, the timeframe across which the deviation is calculated and the prices applicable for deviation outside of the tolerance band. As such, a direct comparison of these values is not appropriate.

² O'Sullivan, J., Power, M., Flynn, M., O'Malley, M., 1999. Modelling of frequency control in an island system. In: IEEE Power Engineering Society 1999 Winter Meeting. Vol. 1. pp. 574–579. Available: <http://ee.ucd.ie/erc/member/1999cosullivan.pdf>

³ A number of countries, such as Germany, Great Britain and Poland do not implement a tolerance band. In Great Britain, there is no explicit tolerance band and generators are expected to follow their Physical Notification level. Where generators fall short of this, they are subject to payment of a System Buy Price. Similarly when over-generating, they receive a System Sell Price. In Poland the TSOs report persistent deviations to the Energy Regulatory Office, who may penalise the relevant generator.

A value of 1 MW has been used for the MW Tolerance in SEM to date and was also applied in the settlement of the electricity market in Ireland prior to the start of SEM. Although the Trading and Settlement Code allows the MW Tolerance parameter value to vary on a Trading Day basis, the System Operators are of the opinion that there are insufficient grounds to justify introducing a varying value, which would increase complexity of the Uninstructed Imbalance mechanism.

Engineering Tolerance ENGTOI

The Engineering Tolerance, a percentage value, defines the percentage tolerance around the dispatch quantity at nominal frequency within which a generating unit is deemed to be complying with its dispatch instruction. Worldwide, there is a range of percentage values used, from 1% upwards, with the majority in the region of 1% to 2%^{4,5}.

As for the MW Tolerance, these values are dependent on a number of factors pertinent to each particular power system and market structure. A value of 1% has been used since market start in SEM and, similarly to the MW Tolerance, this value was also implemented in the electricity market in Ireland prior to SEM.

For these parameter values, at nominal frequency, the tolerance band for a generating unit is the maximum of (a) 1 MW and (b) 1% of the dispatch quantity. The System Operators believe that this minimum tolerance band continues to be reflective of the acceptable practical limits within which dispatchable generation is required to follow its instructions.

⁴ http://www.ieso.ca/imoweb/pubs/interpretBulletins/ib_IMO_MKRI_0001.pdf
⁵ <http://www.ferc.gov/whats-new/comm-meet/2007/021507/E-1.pdf>

5. System per Unit Regulation Parameter (UREG)

5.1 Basis for Parameter

It is expected that, as a result of governor action, a generator's output will vary in response to fluctuations in the system frequency (known as frequency regulation). This can result in Uninstructed Imbalances. However, to recognise that frequency regulation is correct behaviour, the Uninstructed Imbalance mechanism widens the tolerance band when the frequency deviates from nominal to ensure that the DOG and PUG parameters do not apply to imbalances that arise as a result of frequency regulation.

5.2 Proposed Value

The generating units on the island of Ireland normally have a governor droop setting of 4%. The coordination of droop settings ensures that generators share the requirement for regulation in proportion to their size. Therefore, at the start of the SEM, this was the value adopted for UREG. As the technical characteristics of the generators on the system have not changed, no change to this parameter value is necessary.

6. Discount for Over-Generation (DOG) and Premium for Under-Generation (PUG)

6.1 Basis for Parameters

Generators should normally remain within the tolerance band, as discussed in Section 4. If a generator moves outside the tolerance band, additional constraint costs are incurred due to the requirement for corrective action to be taken by the System Operators to avoid compromised system security. It is therefore appropriate to provide economic signals to incentivise generators to remain within the tolerance band.

Over-generation outside of tolerance by a generating unit results in a need for the System Operators to instruct other generating units down from their dispatched levels to lower levels in order to balance supply and demand. Significant over-generation can necessitate dispatching a generator off load to compensate. Under-generation outside of tolerance by a generating unit results in the need to instruct other generating units up from their dispatched levels to higher levels. In the event of unexpected or large under-generation by a generator the System Operator must act in a quick and decisive manner to restore appropriate system balance and reserve targets. This will generally necessitate dispatching on quick-start generators.

From a system security standpoint, over- or under-generation is undesirable as it can result in unnecessary ramping and cycling of units, increasing the likelihood for unit trips and / or increasing wear and tear of generating units.

6.2 Proposed Values

Prior to the start of the SEM, a study⁶ was carried out by the System Operators to evaluate the costs incurred on the system due to Uninstructed Imbalances. Generally, a generating unit that over-generates should be entitled to no more than the average costs of the resources dispatched down to displace the over-generated volumes. In contrast, a generating unit that under-generates should, generally speaking, pay back at least the average costs of the resources dispatched up and on to replace the under-generated volumes.

The results of the study into the costs involved in Uninstructed Imbalances suggested that a value of 0.2 for both DOG and PUG provided an appropriate signal to generators to comply with dispatch instructions within the proposed tolerance band while ensuring that there is recovery of the additional constraint costs incurred. The System Operators believe that, based on operational experience, these values of DOG and PUG are providing sufficient economic signals to cause generators to follow dispatch instructions whenever possible, while being cost related and not overly punitive.

In respect of Interconnectors under test, the System Operators are proposing that DOG and PUG continue to be set to zero for 2016. Until such a time as the SEM design provides for an Interconnector test profile to be submitted, it would be unduly penal to allow DOG and PUG

⁶ Proposed values for Uninstructed Imbalances for the First Trading Year: AIP/SEM/07/430

values to be applied in this case. This has been previously described in the System Operators published paper SEM-12-001a⁷.

⁷ See System Operators published paper SEM-12-001a http://www.allislandproject.org/en/TS_Current_Consultations.aspx?article=356d0517-01b2-4ac0-b677-7749962cfe99

7. Conclusion

It is the System Operators' opinion, based on operational experience since the start of SEM in November 2007, that the Uninstructed Imbalance parameters are providing adequate economic signals at present and that no change is currently warranted to these parameter values.

The proposed values for the parameters used in the calculation of Uninstructed Imbalances are set out in the table below:

	Parameter	Proposed Value
1	Engineering Tolerance, ENGTOL (where $0 \leq \text{ENGTOL} \leq 1$)	0.01
2	MW Tolerance for each Trading Day t, MWTOLt (where $0 \leq \text{MWTOLt}$)	1
3	System per Unit Regulation parameter, UREG	0.04
4	Discount for Over Generation for each Generator Unit u, in each Trading Period h, DOGuh (such that $0 \leq \text{DOGuh} \leq 1$)	0.2
5	Premium for Under Generation for each Generator Unit u in each Trading Period h, PUGuh (such that $0 \leq \text{PUGuh} \leq 1$)	0.2